

AAA OPERATIONS, INC.
STATE CERTIFIED STANDARD BACTERIOLOGICAL WATER ANALYSIS
(POTABILITY TEST) BOTTLE # 14522

AAA OPERATIONS, INC.
 48 Mill Creek Rd.
 PO BOX 134
 Dumont, CO 80436
 303-567-9500 fax 303-567-9501

SAMPLE INFORMATION: Community Noncommunity Private Other
 PWSID 1 5 9 1 1 9
 Routine Special Purpose Repeat for month of ___ / ___ / ___
 Raw Finished Chlorine residual 1.01 Source: Surface Ground

Alpensee
 Name of System

 PO Box 2204 Frisco CO 80424
 Address City State Zip Code

 Summit
 County Owners phone number Owners fax number

SAMPLING INFORMATION:
 Date Collected 6 / 7 / 13 Time 11 : 16 AM PM By JL
 Received by lab 6 / 7 / 13 Time 12 : 11 AM PM By JL

COLILERT RESULTS

TOTAL COLIFORM PRESENCE ABSENCE
 IF PRESENCE, WAS E-COLI PRESENT YES NO

COMMENTS

Sampling Instructions:
 Samples must only be collected in the bottle supplied by AAA. These bottles are sterilized and contain sodium thiosulfate which will neutralize any chlorine that may be in the sample. If there is no chlorine the sodium thiosulfate will have no effect on the sample.
 Water samples must not be taken from water taps of the "swinging arm" types or from taps that have an aerator on the faucet. **DO NOT** use a tap or faucet that is leaking.

- Procedures:**
- 1) Allow the water to run freely for 4 to 5 minutes to flush the pipes.
 - 2) Keep the sample bottle closed until the moment of collecting the sample. While opening the bottle, avoid touching any part of the bottle that will come into direct contact with the water entering the bottle. **DO NOT** rinse the bottle when the sample is being collected.
 - 3) When collecting the sample, fill the bottle with COLD water to the 100 ml mark of the bottle, then replace the cap. Too much or too little sample will invalidate the test.
 - 4) Fill out the above sample request form completely.

Transport:
 Return the sample to AAA OPERATIONS, INC. as soon as possible, within 6 hours of collecting the sample. Keep sample cool from collection to delivery.

Other analysis, equipment and services are available upon request;
 Hardness, Iron, pH, Nitrates, TDS, Metals, Chlorine residuals, etc.
 Call AAA Operations, Inc. (303) 567-9500

Results may be used to establish regional water quality data