AAA OPERATIONS, INC. STATE CERTIFIED STANDARD BACTERIOLOGICAL WATER ANALYSIS, (POTABILITY TEST) BOTTLE # 14536

AAA OPERATIONS, INC. 48 Mill Creek Rd. PO BOX 134 Dumont, CO 80436 303-567-9500 fax 303-567-9501 □ Community Noncommunity □ Private □ Other SAMPLE INFORMATION: Alpensee Name of System PO Box 2204 Zip Code City Address Summit Owners fax number Owners phone number County SAMPLING INFORMATION: Date Collected 7 / / /3 Received by lab 7 / (/ /3 COLILERT RESULTS COMMENTS

Sampling Instructions:

Samples must only be collected in the bottle supplied by AAA. These bottles are sterilized and contain sodium thiosulfate which will neutralize any chlorine that may be in the sample, if there is no chlorine the sodium thiosulfate will have no effect on the sample.

Water samples must not be taken from water taps of the "swinging arm" types or from taps that have an aerator on the faucet. DO NOT us a tap or faucet that is leaking.

Procedures:

Allow the water to run freely for 4 to 5 minutes to flush the pipes.

IF PRESENCE, WAS E-COLI PRESENT TYES NO

2) Keep the sample bottle closed until the moment of collecting the sample. While opening the bottle, avoid touching any part of the bottle that will come into direct contact with the water entering the bottle. <u>DO NOT</u> rinse the bottle when the sample is being collected.

When collecting the sample, fill the bottle with COLD water to the 100 ml mark of the bottle, then replace the cap.
 Too much or too little sample will invalidate the test.

4) Fill out the above sample request form completely.

TOTAL COLIFORM PRESENCE

Transport

Return the sample to AAA OPERATIONS, INC. as soon as possible, within 6 hours of collecting the sample. Keep sample cool from collection to delivery.

Other analysis, equipment and services are available upon request; Hardness, Iron, pH, Nitrates, TDS, Metals, Chlorine residuals, etc. Call AAA Operations, Inc. (303) 567-9500