

ALPENSEE WD Calendar Year 2013 Monitoring Schedule

Public Water System ID	Water System Name	Primary County	Federal System Type	State Source Type	Population
CO0159119	ALPENSEE WD	SUMMIT	Non-Transient, Non-Community	Groundwater	84

Contact Information

All public water systems are required to maintain an Administrative Contact, Treatment Operator (if applicable), and Distribution System Operator (if applicable). If the information below is incorrect or blank please send us a contact update form. This form is available by visiting <http://wqcd.compliance.com>. The contact update form is located under 'Facility Operator Certification'. For operator certification information please visit <http://www.ocpweb.com>. You may search for individual operator certification levels/expiration by clicking on the 'Information' menu bar and selecting 'State Certified Operators'.

Administrative Contact	Treatment Operator	Distribution System Operator
DON SCOTTY	SCOTT PHILLIP MEYER	SCOTT PHILLIP MEYER

General Information

The Drinking Water Monitoring Schedule is provided for your reference and to assist in developing your sampling schedule. An example schedule has been posted to <http://wqcd.compliance.com/schedules>. Schedules will be posted to the website every Wednesday to show up-to-date information (please allow a few weeks for us to process your sample results data). If you have questions about your schedule please contact your representative ([contact information](#)) or call us at 303-692-3556.

Laboratory sampling results may be submitted to the Compliance Assurance Unit via email to cdpbe.drinkingwater@state.co.us or fax 303-758-1398. Please do not email results directly to Compliance Assurance personnel unless otherwise directed. Please remember to use the Sample Point ID and the Facility ID listed below on all state reporting forms when submitting laboratory sample results.

- All systems that treat groundwater with a chemical disinfectant must monitor residuals at the entry point(s) to the distribution system **at least once per week**. The entry point residual must not be below 0.2 mg/L for more than 72 hours. When groundwater is treated with surface water or is 4-Log approved the system must comply with the monitoring requirements in the 'Non-Distribution System Sample Schedules' section and the disinfectant residual level requirements in the 'Facility Specific Levels' section.

Monitoring Information

Distribution System Sample Schedules		
Facility ID	Facility Name	Facility Type
DS001	DISTRIBUTION SYSTEM	Distribution System
Microorganisms and Disinfectants		
TOTAL COLIFORM BACTERIA (TCR) Sample Schedule:		Collection Period:
1 sample(s) per Quarter during the collection period		January 1, 2013 to December 31, 2013
CHLORINE Sample Schedule:		
Measure every time you collect a TOTAL COLIFORM BACTERIA (TCR) sample		
Lead and Copper		
LEAD AND COPPER Sample Schedule:		*Collection Period:*
5 sample(s) per Year		June 1, 2013 to September 30, 2013
Collection Restriction: Sample(s) must be collected between June 1 and September 30		

Non-Distribution System Sample Schedules

Facility ID	Facility Name	Facility Type	Sample Point ID	Sample Point Name	Sample Point Type
004	TANK	Storage	004	ENTRY POINT	Entry Point
Yearly Schedules					
VOLATILE ORGANICS GROUP Sample Schedule:				Collection Period:	
1 sample(s) per Year				January 1, 2013 to December 31, 2013	
Satisfied Schedules					
NITRATE Sample Schedule:				Collection Period:	
1 sample(s) per Year				January 1, 2013 to December 31, 2013 **Sample Result(s) Received**	

Facility Specific Levels

Facility ID	Facility Name	Facility Type
DS001	DISTRIBUTION SYSTEM	Distribution System
Analyte Name	Level	Level Type
CHLORINE	Detectable	Minimum
CHLORINE	4.0 mg/L	Maximum

Time Period Definitions

Time Period	Start Date	End Date
First Quarter	January 1, 2013	March 31, 2013
Second Quarter	April 1, 2013	June 30, 2013
Third Quarter	July 1, 2013	September 30, 2013
Fourth Quarter	October 1, 2013	December 31, 2013
First 6 Months	January 1, 2013	June 30, 2013
Second 6 Months	July 1, 2013	December 31, 2013
Year	January 1, 2013	December 31, 2013

Analyte Group Definitions

Analyte Group Name	Analytes in Group	Number of Analytes in Group
VOLATILE ORGANICS GROUP	1,1,1-TRICHLOROETHANE 1,1,2-TRICHLOROETHANE 1,1-DICHLOROETHYLENE 1,2,4-TRICHLOROBENZENE 1,2-DICHLOROETHANE 1,2-DICHLOROPROPANE BENZENE CARBON TETRACHLORIDE CHLOROBENZENE CIS-1,2-DICHLOROETHYLENE DICHLOROMETHANE ETHYLBENZENE O-DICHLOROBENZENE P-DICHLOROBENZENE STYRENE TETRACHLOROETHYLENE TOLUENE TRANS-1,2-DICHLOROETHYLENE TRICHLOROETHYLENE VINYL CHLORIDE XYLENES (TOTAL)	21