



COLORADO
Department of Public
Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

September 12, 2014

Don Skotty
P.O. Box 2204
Frisco, CO
80443

RESCIND BOIL WATER TIER 1 PUBLIC NOTIFICATION REQUIREMENT
Alpensee Water District, PWSID# CO0159119
Summit County

Dear Mr. Skotty:

The Colorado Department of Public Health and Environment-Water Quality Control Division (Department) issued a "Boil Water Advisory" for the Alpensee Water District (System) on September 9, 2014 due to a malfunction that caused a back-up of the water storage tank into the pump room possibly causing contamination of the drinking water.

The Department has received the following information from the System:

1. Written description of what the problem was and the actions taken to correct the underlying problem.
2. Confirmation that pressure was restored and the system was flushed.
3. Results of 3 microbiological samples that were obtained from the distribution system after the system had been disinfected and flushed as well as normal chlorine residual data.
4. "Certificate of Delivery" Form along with a copy of the Tier 1 Public Notice sent to each customer.

Based upon the data provided by the System, the September 9, 2014 "Boil Water Advisory" is hereby rescinded. Effective date of this action is September 12, 2014. The affected customers should be notified of the lifting of the "Boil Water Advisory." Public notice of the lifting of the "Boil Water Advisory" should include contact information for the water system and should be provided in a similar manner to which the initial "Boil Water Advisory" was issued.

If you have any further questions, please contact me at 303-692-3605 or via email at David.Dani@state.co.us.



Sincerely,



David Dani
Local Assistance Unit
Water Quality Control Division

cc: Drinking Water File CO0159119

Martha Rudolph, Environmental Programs Director, CDPHE
Mark Salley, Communications Office, CDPHE
Karin McGowan, Legislative Office, CDPHE
Ron Falco, Safe Drinking Water Program Manager and acting Water Quality Control Division Director, CDPHE
Meghan Trubee, Communications, WQCD-CDPHE
Tyson Ingels, Engineering Section, WQCD-CDPHE
Jennifer Robinett, Compliance Section Manager, WQCD-CDPHE
Nicole Graziano, Safe Drinking Water Compliance Assurance, WQCD-CDPHE
Margaret Talbott, Safe Drinking Water Compliance Assurance, WQCD-CDPHE
Bret Icenogle, Engineering Section Manager, WQCD-CDPHE
Greg Naugle, Field Services Section Manager, WQCD-CDPHE
Kelly Jacques, Field Services Section, WQCD-CDPHE
Heather Drissel, Field Services Section, WQCD-CDPHE
Cathy Heald, Field Services Section, WQCD-CDPHE
Armando Herald, Local Assistance Unit, WQCD-CDPHE
Lyle Moore, Director, Office of Emergency Preparedness and Response, CDPHE
Greg Stasinis, Office of Emergency Preparedness and Response, CDPHE
Alicia Cronquist, Division of Epidemiology, CDPHE
Therese Pilonetti, Environmental Health and Sustainability, CDPHE
Amy Schultz, Compliance Assurance, WQCD-CDPHE
Dan Hendershott, Summit County Environmental Health Department, danh@co.summit.co.us
Jan Trahan, Summit County Environmental Health Department, janett@co.summit.co.us
Scott Meyer, Alpengsee Water District operator, aaa_admin@aaaoperations.com