

Analytical Results

TASK NO: 150720029

Report To: Linda Dibble
Company: Alberts Water/Wastewater Specialists, Inc.
737 S. Lemay
Suite B4-411
Fort Collins CO 80524

Bill To: Linda Dibble
Company: Alberts Water/Wastewater Specialists, Inc.
737 S. Lemay
Suite B4-411
Fort Collins CO 80524

Task No.: 150720029
Client PO:
Client Project: Alpanse Water District CO0159119

Date Received: 7/20/15
Date Reported: 7/27/15
Matrix: Water - Drinking

Customer Sample ID 663 Alpanse
Sample Date/Time: 7/16/15 6:00 AM
Lab Number: 150720029-01

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.345	EPA 200.8	0.001	7/24/15	1.3
Lead (mg/L)	0.002	EPA 200.8	0.001	7/24/15	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 150720029

Report To: Linda Dibble
Company: Alberts Water/Wastewater Specialists, Inc.
737 S. Lemay
Suite B4-411
Fort Collins CO 80524

Bill To: Linda Dibble
Company: Alberts Water/Wastewater Specialists, Inc.
737 S. Lemay
Suite B4-411
Fort Collins CO 80524

Task No.: 150720029
Client PO:
Client Project: Alpanse Water District CO0159119

Date Received: 7/20/15
Date Reported: 7/27/15
Matrix: Water - Drinking

Customer Sample ID 910 Alpanse
Sample Date/Time: 7/19/15 9:30 AM
Lab Number: 150720029-02

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.083	EPA 200.8	0.001	7/24/15	1.3
Lead (mg/L)	0.003	EPA 200.8	0.001	7/24/15	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 150720029

Report To: Linda Dibble
Company: Alberts Water/Wastewater Specialists, Inc.
737 S. Lemay
Suite B4-411
Fort Collins CO 80524

Bill To: Linda Dibble
Company: Alberts Water/Wastewater Specialists, Inc.
737 S. Lemay
Suite B4-411
Fort Collins CO 80524

Task No.: 150720029
Client PO:
Client Project: Alpanse Water District CO0159119

Date Received: 7/20/15
Date Reported: 7/27/15
Matrix: Water - Drinking

Customer Sample ID 151 Onmaha
Sample Date/Time: 7/18/15 8:00 AM
Lab Number: 150720029-03

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.181	EPA 200.8	0.001	7/24/15	1.3
Lead (mg/L)	0.001	EPA 200.8	0.001	7/24/15	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Report To: Linda Dibble
Company: Alberts Water/Wastewater Specialists, Inc.
737 S. Lemay
Suite B4-411
Fort Collins CO 80524

Bill To: Linda Dibble
Company: Alberts Water/Wastewater Specialists, Inc.
737 S. Lemay
Suite B4-411
Fort Collins CO 80524

Task No.: 150720029
Client PO:
Client Project: Alpanse Water District CO0159119

Date Received: 7/20/15
Date Reported: 7/27/15
Matrix: Water - Drinking

Customer Sample ID 10 Farmers Lane
Sample Date/Time: 7/19/15 9:45 AM
Lab Number: 150720029-04

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.176	EPA 200.8	0.001	7/24/15	1.3
Lead (mg/L)	0.005	EPA 200.8	0.001	7/24/15	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 150720029

Report To: Linda Dibble
Company: Alberts Water/Wastewater Specialists, Inc.
737 S. Lemay
Suite B4-411
Fort Collins CO 80524

Bill To: Linda Dibble
Company: Alberts Water/Wastewater Specialists, Inc.
737 S. Lemay
Suite B4-411
Fort Collins CO 80524

Task No.: 150720029
Client PO:
Client Project: Alpanse Water District CO0159119

Date Received: 7/20/15
Date Reported: 7/27/15
Matrix: Water - Drinking

Customer Sample ID WTP
Sample Date/Time: 7/19/15 10:00 AM
Lab Number: 150720029-05

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.581	EPA 200.8	0.001	7/24/15	1.3
Lead (mg/L)	BDL	EPA 200.8	0.001	7/24/15	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Drinking Water Chain of Custody



LABORATORIES, INC.

Brighton Lab
240 South Main Street
Brighton, CO 80601

Lakewood Lab
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313
Fax: 303-659-2315

www.coloradolab.com

Report To Information		Bill To Information (If different from report to)		State Form / Project Information	
Company Name: <u>Aurora</u>	Company Name: _____	PWSID: <u>CO0159119</u>	Address: _____		
Contact Name: <u>Linda Pibb</u>	Contact Name: _____	System Name: <u>Alpensee WD</u>	City: _____	State: _____	Zip: _____
Address: _____	Address: _____	City: _____	State: _____	Zip: _____	City: _____
City: _____	State: _____	City: _____	State: _____	Zip: _____	City: _____
Phone: _____	Fax: _____	Phone: _____	Fax: _____	County: _____	County: _____
Email: _____	Email: _____	Compliance Samples: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Send Forms to State: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
Sampler Name: <u>MIKE STACK</u>	PO No.: _____				

Task Number

CAL Task No.
150720029

RNL

Date	Time	Client Sample ID / LP Code	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226	Radium 228	Radon	Uranium
7/16	660	663A Alpensee	1														X												
7/19	930	916 Alpensee	1														X												
7/18	900	151 Coachg	1														X												
7/19	945	10 Farmers	1														X												
7/19	1000	WTP	1														X												
7/19	1130	910 Alpensee	4														X												
7/19	1030	004 BP	4														X												

Instructions:

C/S Info:

Seals Present Yes No Headspace Yes No

Delivered Via: Hand

C/S Charge

Temp 24 °C/lc

Sample Pres Yes No

Relinquished By: <u>M. Stack</u>	Date/Time: <u>7/20/15</u>	Received By: <u>[Signature]</u>	Date/Time: <u>7/20/15 1400</u>	Relinquished Via: _____	Date/Time: _____	Received By: _____	Date/Time: _____
----------------------------------	---------------------------	---------------------------------	--------------------------------	-------------------------	------------------	--------------------	------------------

1402