

Red, White, & Blue Fire Department

Breckenridge, CO

This report was generated on 11/4/2019 12:07:25 PM



Hydrants Flow Tested for Date Range

Start Date: 10/01/2019 | End Date: 10/31/2019

HYD. ID	ADDRESS	LOCATION	TEST DATE	START TIME	END TIME	STATIC	RESIDUAL	DOWNSTREAM (HYD. ID)	FLOW @ DES. PRESS	DISTRICT
Zone Unknown										
Alpensee 01	76 Gold Piece DR #118Breckenridge, CO 80424	End of Gold Piece Drive	10/16/2019	12:56	13:00	70 PSI	0 PSI	1404 GPM (Hydrant 14)	1170 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks:		TESTED BY: Nelson, Jay						
Alpensee 02	38 Gold Piece DR Breckenridge, CO 80424		10/16/2019	12:58	13:02	90 PSI	0 PSI	1453 GPM (HYDRANT 17)	1268 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks:		TESTED BY: Nelson, Jay						
Alpensee 03	1030 Alpensee DR #1058Breckenridge, CO 80424		10/16/2019	13:04		90 PSI	0 PSI	1300 GPM (Hydrant 12)	1135 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks:		TESTED BY: Nelson, Jay						
Alpensee 04	110 Omaha DR Breckenridge, CO 80424		10/16/2019	14:14		80 PSI	0 PSI	1300 GPM (Hydrant 12)	1112 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks:		TESTED BY: Nelson, Jay						
Alpensee 05	110 Omaha DR Breckenridge, CO 80424		10/16/2019	13:09		85 PSI	0 PSI	1300 GPM (Hydrant 12)	1124 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks:		TESTED BY: Nelson, Jay						
Alpensee 06	964 Alpensee DR Breckenridge, CO 80424		10/16/2019	13:10		90 PSI	10 PSI	1300 GPM (Hydrant 12)	1209 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks:		TESTED BY: Nelson, Jay						
Alpensee 07	964 Alpensee DR Breckenridge, CO 80424		10/16/2019	13:11		100 PSI	25 PSI	1300 GPM (Hydrant 12)	1346 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks:		TESTED BY: Nelson, Jay						
Alpensee 08	95 Silverdollar DR Breckenridge, CO 80424		10/16/2019	13:14		100 PSI	20 PSI	1300 GPM (Hydrant 12)	1300 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks:		TESTED BY: Nelson, Jay						
Alpensee 09	131 Silverdollar DR Breckenridge, CO 80424		10/16/2019	13:19		100 PSI	20 PSI	1300 GPM (Hydrant 12)	1300 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks:		TESTED BY: Nelson, Jay						
Alpensee 10	586 Alpensee DR Breckenridge, CO 80424		10/16/2019	13:25		120 PSI	45 PSI	1300 GPM (Hydrant 12)	1518 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks:		TESTED BY: Nelson, Jay						
Alpensee 11	586 Alpensee DR Breckenridge, CO 80424		10/16/2019	13:43		150 PSI	75 PSI	1300 GPM (Hydrant 12)	1749 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks:		TESTED BY: Nelson, Jay						

HYD. ID column sorts alphanumerically rather than strictly numerically because the Hydrant ID field can also contain letters and certain characters at the discretion of the Department entering the data.

HYD. ID	ADDRESS	LOCATION	TEST DATE	START TIME	END TIME	STATIC	RESIDUAL	DOWNSTREAM (HYD. ID)	FLOW @ DES. PRESS	DISTRICT
Alpensee 12	76 Alpensee CT Breckenridge, CO 80424		10/16/2019	13:45		160 PSI	75 PSI	1186 GPM (Hydrant 13)	1552 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks: TESTED BY: Nelson, Jay								
Alpensee 13	81 Alpensee CT Breckenridge, CO 80424		10/16/2019	13:47		140 PSI	70 PSI	1300 GPM (Hydrant 12)	1739 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks: TESTED BY: Nelson, Jay								
Alpensee 14	107 Alpensee DR Breckenridge, CO 80424		10/16/2019	13:52		180 PSI	90 PSI	1300 GPM (Hydrant 12)	1773 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks: TESTED BY: Nelson, Jay								
Alpensee 15	530 Alpensee DR Breckenridge, CO 80424		10/16/2019	13:54		175 PSI	90 PSI	1300 GPM (Hydrant 12)	1798 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks: TESTED BY: Nelson, Jay								
Alpensee 16	10 Farmers LN Breckenridge, CO 80424		10/16/2019	14:03		175 PSI	90 PSI	1300 GPM (Hydrant 12)	1798 @ 20 PSI	Alpensee Water District
Flow Test Results: No Data Provided		Remarks: TESTED BY: Nelson, Jay								
Alpensee 17	10 Farmers LN Breckenridge, CO 80424		10/16/2019	14:10		170 PSI	90 PSI	1300 GPM (Hydrant 12)	1825 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks: TESTED BY: Nelson, Jay								
Alpensee 18	564 School RD #584Breckenridge, CO 80424		10/16/2019	14:16		170 PSI	100 PSI	1300 GPM (Hydrant 12)	1961 @ 20 PSI	Alpensee Water District
Flow Test Results: Pass		Remarks: TESTED BY: Nelson, Jay								

HYD. ID column sorts alphanumerically rather than strictly numerically because the Hydrant ID field can also contain letters and certain characters at the discretion of the Department entering the data.