



**Lead and Copper Certified Laboratory Report Form**

**Submit Online: [wqcdcompliance.com/login](http://wqcdcompliance.com/login) (preferred); Fax (303) 758-1398**

**WQCD-B2-Drinking Water CAS**

**4300 Cherry Creek Drive South; Denver, CO 80246-1530**

**LCR - Results**

Revision: 11/01/2016

Section I (Supplied or Completed by Public Water System)		Section II (Supplied or Completed by Certified Laboratory)	
<b>Public Water System Information</b>		<b>Certified Laboratory Information</b>	
PWSID#: CO0159119	Facility ID: DS001	Laboratory ID: CO015	
System Name: Alpengsee Water District		Laboratory Name: Colorado Analytical Laboratory	
Contact Person: Linda Dibble	Phone #: 970-494-1610	Contact Person: Customer Service	Phone: 303-659-2313
Comments:			

Section III (Supplied or Completed by Public Water System)		Section IV (Supplied or Completed by Certified Laboratory)									
Sample Date	Collector	Sample Pt ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
8/16/21	Ron Torres	LCR003	475 Alpengsee	8/16/21	8/19/21	210816078-01	Copper	EPA 200.8	1.3	0.001	<b>0.056</b>
							Lead	EPA 200.8	0.015	0.001	<b>0.001</b>

NT: Not Tested  
 Lab MRL: Laboratory Minimum Reporting Level  
 BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter  
 AL: Action Level



### Drinking Water Chain of Custody

Report To Information		Bill To Information (If different from report to)		Project Information	
Company Name: <u>Alps</u>	Company Name:	PWSID: <u>CO 0159119</u>	System Name: <u>Alpensee WD</u>		
Contact Name: <u>Linda Dibala</u>	Contact Name:	Compliance Samples: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>			
Address:	Address:	Send Results to CDPHE: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>			
City: State: Zip:	City: State: Zip:	Task Number: <b>CAL Task</b>			
Phone:	Phone:	210816078			
Email:	Email:	NAB			
Sample Collector: <u>Ren Torres</u>	PO Number:				
Sample Collector Phone: <u>970-419-9282</u>					

**Commerce City Lab**  
 10411 Heinz Way  
 Commerce City CO 80640  
  
**Lakewood Service Center**  
 12860 W. Cedar Dr, Suite 100A  
 Lakewood CO 80228  
  
**Phone: 303-659-2313**  
  
[www.coloradolab.com](http://www.coloradolab.com)

PHASE I, II, V Drinking Water Analyses (check requested analysis)		Subcontract Analyses																													
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L)	P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothal	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk/Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite	
8-16-21	0940	162003-475 Alpensee	1																												
Instructions:		C/S Info:		Seals Present Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		Headspace Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		Temp. °C/F: <u>16.4</u>		Sample Pres. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		Date/Time: <u>8-16-21 1524</u>		Date/Time: <u>8-16-21 1524</u>		Date/Time: <u>8-16-21 1524</u>		Date/Time: <u>8-16-21 1524</u>		Date/Time: <u>8-16-21 1524</u>		Date/Time: <u>8-16-21 1524</u>		Date/Time: <u>8-16-21 1524</u>		Date/Time: <u>8-16-21 1524</u>		Date/Time: <u>8-16-21 1524</u>			

**Analytical Results**

**TASK NO: 210816078**

**Report To:** Linda Dibble

**Company:** Alberts Water/Wastewater Specialists, Inc.  
425 John Deere Drive  
Suite #5  
Fort Collins CO 80524

**Bill To:** Accounts Payable

**Company:** Alberts Water/Wastewater Specialists, Inc.  
425 John Deere Drive  
Suite #5  
Fort Collins CO 80524

**Task No.:** 210816078  
**Client PO:**  
**Client Project:** Alpanse Water District CO0159119

**Date Received:** 8/16/21  
**Date Reported:** 8/24/21  
**Matrix:** Water - Drinking

**Customer Sample ID** 475 Alpanse  
**Sample Date/Time:** 8/16/21 9:40 AM  
**Lab Number:** 210816078-01

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	<b>0.056</b>	EPA 200.8	0.001	8/19/21	1.3
Lead (mg/L)	<b>0.001</b>	EPA 200.8	0.001	8/19/21	0.015

**Abbreviations/ References:**

PQL = Practical Quantification Limit  
mg/L = Milligrams Per Liter or PPM  
BDL = Below Detectable Levels  
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

