



Colorado Department
of Public Health
and Environment

Organic Chemicals Certified Laboratory Report Form
WQCD - Drinking Water CAS
Submit Online at <http://www.wqcdcompliance.com/login>

Revised 4/13/2015

VOC/SOC

Section I (Supplied or Completed by Public Water System)		Section II (Supplied or Completed by Certified Laboratory)	
Public Water System Information		Certified Laboratory Information	
PWSID#: CO0159119		Laboratory ID: CO015	
System Name: Alpengsee Water District		Laboratory Name: Colorado Analytical Laboratory	
Contact Person: Vanessa Mancill	Phone #: 970-494-1610	Contact Person: Customer Service	Phone: 303-659-2313
Comments:	Do Samples Need to be Composited BY THE LAB? <input type="checkbox"/>	Comments:	

PWSID#: CO0159119	Section III (Supplied or Completed by Public Water System)			
Sample Date: 1/25/23	Collector: Dan Oconnor	Facility ID (On Schedule): 004	Sample Pt ID (On Schedule): 004	

Section IV Volatile Organic Chemicals (Supplied or Completed by Certified Laboratory)								
Lab Receipt Date	Lab Analysis Date	Lab Sample ID	Analyte Name	CAS No.	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
1/25/23	1/26/23	230125076-01A	1,1,1-Trichloroethane	71-55-6	EPA-524.2	200	0.5	BDL
1/25/23	1/26/23	230125076-01A	1,1,2-Trichloroethane	79-00-5	EPA-524.2	5	0.5	BDL
1/25/23	1/26/23	230125076-01A	1,1-Dichloroethylene	75-35-4	EPA-524.2	7	0.5	BDL
1/25/23	1/26/23	230125076-01A	1,2,4-Trichlorobenzene	120-82-1	EPA-524.2	70	0.5	BDL
1/25/23	1/26/23	230125076-01A	1,2-Dichloroethane	107-06-2	EPA-524.2	5	0.5	BDL
1/25/23	1/26/23	230125076-01A	1,2-Dichloropropane	78-87-5	EPA-524.2	5	0.5	BDL
1/25/23	1/26/23	230125076-01A	Benzene	71-43-2	EPA-524.2	5	0.5	BDL
1/25/23	1/26/23	230125076-01A	Carbon Tetrachloride	56-23-5	EPA-524.2	5	0.5	BDL
1/25/23	1/26/23	230125076-01A	Monochlorobenzene	108-90-7	EPA-524.2	100	0.5	BDL
1/25/23	1/26/23	230125076-01A	cis-1,2-Dichloroethylene	156-59-2	EPA-524.2	70	0.5	BDL
1/25/23	1/26/23	230125076-01A	Dichloromethane	75-09-2	EPA-524.2	5	0.5	BDL
1/25/23	1/26/23	230125076-01A	Ethylbenzene	100-41-4	EPA-524.2	700	0.5	BDL
1/25/23	1/26/23	230125076-01A	o-Dichlorobenzene	95-50-1	EPA-524.2	600	0.5	BDL
1/25/23	1/26/23	230125076-01A	Para-Dichlorobenzene	106-46-7	EPA-524.2	75	0.5	BDL
1/25/23	1/26/23	230125076-01A	Styrene	100-42-5	EPA-524.2	100	0.5	BDL
1/25/23	1/26/23	230125076-01A	Tetrachloroethylene	127-18-4	EPA-524.2	5	0.5	BDL
1/25/23	1/26/23	230125076-01A	Toluene	108-88-3	EPA-524.2	1000	0.5	BDL
1/25/23	1/26/23	230125076-01A	trans-1,2-Dichloroethylene	156-60-5	EPA-524.2	100	0.5	BDL
1/25/23	1/26/23	230125076-01A	Trichloroethylene	79-01-6	EPA-524.2	5	0.5	BDL
1/25/23	1/26/23	230125076-01A	Vinyl chloride	75-01-4	EPA-524.2	2	0.5	BDL
1/25/23	1/26/23	230125076-01A	Xylenes (total)	1330-20-7	EPA-524.2	10000	0.5	BDL

NT: Not Tested ug/L: Micrograms per Liter MCL: Maximum Contaminant Level BDL Below Laboratory MRL A less than sign (<) may also be used.

230125076-01 Y

1/1
1/31/23

Drinking Water Chain of Custody



Commerce City Lab
 10411 Heinz Way
 Commerce City CO 80640

Lakewood Service Center
 610 Garrison Street, Unit E
 Lakewood CO 80215

Phone: 303-659-2313

www.coloradolab.com

Report To Information			Bill To Information (If different from report to)			Project Information		
Company Name: <u>AWWS</u>			Company Name: _____			PWSID: <u>CO 0159119</u>		
Contact Name: <u>Jade Meyer</u>			Contact Name: _____			System Name: <u>Alpensee Water District</u>		
Address: _____			Address: _____			Compliance Samples: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
City: _____	State: _____	Zip: _____	City: _____	State: _____	Zip: _____	Send Results to CDPHE: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
Phone: _____			Phone: _____			CAL Task 230125076 JML		
Email: _____			Email: _____					
Sample Collector: <u>Dan O'Connor</u>			Sample Collector: _____			Task Number (Lab Use Only): _____		
Sample Collector Phone: <u>970 9807594</u>			PO Number: _____					

			PHASE I, II, V Drinking Water Analyses (check requested analysis)																Subcontract Analyses											
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothal	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite	
1-25	10:45	EP004	5						X									X		X										

Instructions:

C/S Info: _____ Seals Present Yes No Headspace Yes No

Delivered Via: HD C/S Charge Temp. °C/Ice 2.4 Sample Pres. Yes No

Relinquished By: <u>[Signature]</u>	Date/Time: <u>1-25 13:29</u>	Received By: <u>[Signature]</u>	Date/Time: <u>1/25/13</u>	Relinquished By: _____	Date/Time: _____	Received By: _____	Date/Time: _____
-------------------------------------	------------------------------	---------------------------------	---------------------------	------------------------	------------------	--------------------	------------------